DECLARATION OF PERFORMANCE

No / CPR / / 2019 / v2 - EN

- Unique identification code of the product type: fire resistant rolling shutter, type El120
- 2. Intended use/es: to be used as a vertical, mobile partition to close the passage between fire separation zones at industrial premises and public buildings
- 3. Manufacturer:
- 4. System/s of AVCP: System 1; System 3
- 5. Harmonised standard: EN 16034:2014; EN 13241:2003+A2:2016
- 6. Notified body/ies:

Notified Body No. 2434 - Centrum Techniki Okrętowej S.A. Ośrodek Certyfikacji Wyrobów, ul. Szczecińska 65, 80-392 Gdańsk, Poland (System 1)

Certificate of constancy of performance No. 2434-CPR-0036

Notified Body No. 1488 - Instytut Techniki Budowlanej (ITB); ul. Filtrowa 1, 00-611 Warszawa; Poland (System 3)

7. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification	
Resistance to fire	El ₁ 60, El ₂ 120, EW 120		
Smoke control	NPD	EN 16034:2014	
Ability to release	fulfils		
Self-closing	С		
Durability to ability to release	fulfils		
Durability of self-closing against degradation	category of use 0		
Durability of self-closing against ageing (corrosion)	fulfils		
Watertightness	NPD		
Release of dangerous substances	fulfils	EN 13241:2003+A2:2016	
Resistance to wind load	class 1		
Thermal resistance	NPD		
Air permeability	NPD		
Safe opening	fulfils		
Definition of geometry of glass components	NPD		
Mechanical resistance and stability	fulfils		
Operating forces	fulfils		
Durability of watertightness, thermal resistance and air permeability against degradation	NPD		

^{*)} NPD - no performance determined

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Czołowo, (02 October 202	0	
15/22			
	[signature]		