

DECLARATION OF PERFORMANCE

No [REDACTED] / CPR / [REDACTED] / 2019 - EN

1. Unique identification code of the product - type: **fire resistant rolling shutter, type [REDACTED] EI120**
2. Intended use/es: **to be used as a vertical, mobile partition to close the passage between fire separation zones at industrial premises and public buildings**
3. Manufacturer: [REDACTED]
4. System/s of AVCP: **System 1; System 3**
5. Harmonised standard: **EN 16034:2014; EN 13241:2003+A2:2016**
6. Notified body/ies: [REDACTED]
**Centrum Techniki Okrętowej S.A. Ośrodek Certyfikacji Wyrobów, ul. Szczecińska 65,
80-392 Gdańsk, Poland**
7. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification
Resistance to fire	EI ₁ 60, EI ₂ 120, EW 120	EN 16034:2014
Smoke control	NPD	
Ability to release	fulfils	
Self-closing	C	
Durability to ability to release	fulfils	
Durability of self-closing against degradation	category of use 0	
Durability of self-closing against ageing (corrosion)	fulfils	
Watertightness	NPD	EN 13241:2003+A2:2016
Release of dangerous substances	fulfils	
Resistance to wind load	class 1	
Thermal resistance	NPD	
Air permeability	NPD	
Safe opening	fulfils	
Definition of geometry of glass components	NPD	
Mechanical resistance and stability	fulfils	
Operating forces	fulfils	
Durability of watertightness, thermal resistance and air permeability against degradation	NPD	

¹⁾ NPD – no performance determined

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

[REDACTED]

Konarskie, 09.04.2019

[REDACTED]

[signature]